

Town of Ulysses
MONTHLY WATER REPORT
July 2021

WATER DISTRICT 3:

- 250 users connected & using
- 52 in district and tapped into water main but continue to use private well (not using town water)

Testing

The following tests are mandated by the Tompkins County Health Dept.

<u>Test</u>	<u>Frequency</u>	<u>This month's result</u>
bacteria	Monthly	negative
DBP/THMs	Monthly	41ppm on Hyd. #60 (max of 80 allowed)
chlorine	Daily	Within normal range
Lead & copper	Every 3 yrs	<i>(next due in 2022)</i>

Financials

- Quarterly billings (Feb. May, Aug. & Nov.)

Maintenance

- Meters switched to radiohead (remote) meter readers:
 - 83 switched
 - 148 outstanding
 - # does not include trailer park sub-meters but does include master meter
 - estimated cost= \$195 each
- # Water main breaks discovered – 0
- Hydrant flushing:
 - Perry City Rd, Jacksonville Rd., Swamp College completed
 - In progress: Rte. 96, Cold Springs & Van Dorn's Rd.
- Tank/aerator updates:
 - TTHM rates reduced
 - Unsure of status of gate on top of tank

Water hook up requests (none completed)

- 1 in district, 2 out of district

Trainings

- Water District Operator is scheduled for training in August.

Water notifications to customers

- Preparing to send update along with water bills ~8/16 re:
 - Aerator & TTHM levels
 - Culvert replacement on Route 96 will shut down water temporarily

Water notifications to town from DOH

- *None this month*

Meetings

- Informal talks with Supervisor, Attorney, engineers, Bolton Point, and town staff on out-of-district user requests

OTHER TOWN OF ULYSSES WATER DISTRICTS:

WATER DISTRICT 1- CARS + 2 other users

WATER DISTRICT 2- ShurSave

WATER DISTRICT 4- 3 properties on Dubois Rd.

Submitted by Carissa Parlato, Water District Clerk, 8/6/21